

Our Ref PC/JCS

26 April 2000

Mr J Platt
Jctseal
38 Hilton Road
Ferndown
Dorset
BH22 9QS

Dear Mr Platt


RE: JETSEAL LIFE CYCLE TEST (MK2)

I am writing to confirm that the above valve has now completed the endurance test that you requested.

The valve was first subjected to all relevant tests and examinations contained in WRc document IGN 5-50-01.

The test was halted after 560,000 cycles which equates to a life of, approx 80 years. The valve was still operational at that time.

Yours sincerely



Philip A Chalk